

State of Montana
 Department of Health and Human Services
Environmental Laboratory
 1400 Broadway, Room B 206 Helena, MT 59620
 phone: 406-444-3444 fax: 406-444-5527

RESULTS OF CHEMICAL ANALYSIS

Billing ID: G0043694

Mn KING RANCH SUBDIVISION
 CRAIG MILAM
 PO BOX 118
 FRENCHTOWN, MT 59834

Account ID #:	G0043694
PWSID #:	MT0004158
Collected:	9/18/24
Time:	10:00
By:	Charles Weihe
Received Date:	9/26/24 7:38
Sample Type:	RT
Matrix:	Water
Compliance	Y
Report Date:	10/29/2024
Print Date:	10/29/2024

Lab #: 2409505-01

Sample ID: RW002 Well 1 05-08-96 E GWIC 155829
 WL002

TEST	FLAG	RESULT	UNITS	**EPA Drinking Water Limit	ANALYSIS DATE	METHOD
------	------	--------	-------	----------------------------	---------------	--------

Metals by EPA 200.7

Manganese	<	0.005	mg/L	0.3	10/28/2024	200.7
-----------	---	-------	------	-----	------------	-------

Reviewed By: 

Comments: WELL 1 05-08-96 E

Flags: < = less than
 > = greater than
 H = above EPA limit for drinking water
 * = holding time exceeded
 ** Not all parameters have EPA Drinking Water Limits

Qualifiers: No Qualifiers were applied to the sample results.

State of Montana
 Department of Health and Human Services
Environmental Laboratory
 1400 Broadway, Room B 206 Helena, MT 59620
 phone: 406-444-3444 fax: 406-444-5527

RESULTS OF CHEMICAL ANALYSIS

Billing ID: G0043694

Mn KING RANCH SUBDIVISION
 CRAIG MILAM
 PO BOX 118
 FRENCHTOWN, MT 59834

Lab #: 2409505-02

Sample ID: RW003 Well 2 05-09-96 GWIC 155830
 WL003

Account ID #:	G0043694
PWSID #:	MT0004158
Collected:	9/18/24
Time:	10:00
By:	Charles Weihe
Received Date:	9/26/24 7:38
Sample Type:	RT
Matrix:	Water
Compliance	Y
Report Date:	10/29/2024
Print Date:	10/29/2024

TEST	FLAG	RESULT	UNITS	**EPA Drinking Water Limit	ANALYSIS DATE	METHOD
------	------	--------	-------	----------------------------	---------------	--------

Metals by EPA 200.7
 Manganese

< 0.005 mg/L 0.3 10/28/2024 200.7

Reviewed By:

Comments: WELL 2 05-09-96 W

Flags: < = less than
 > = greater than
 H = above EPA limit for drinking water
 * = holding time exceeded
 ** Not all parameters have EPA Drinking Water Limits

Qualifiers: No Qualifiers were applied to the sample results.